


Kern 1
5VA Cl.: 0,2SFSS5

Kern 2
7VA Cl.: 1




Kern 3
10VA Cl.:5P30

1S1-1S2 1500/1A 2S1-2S2 1500/1A
1S1-1S3 2500/1A 2S1-2S3 2500/1A

3S1-3S2 1500/1A
3S1-3S3 2500/1A

1S1 1S2 1S3 2S1 2S2 2S3

3S1 3S2 3S3



A	Erstellung	11.3.98	DNL	Datum	Name	Maßstab: 1:2	Gewicht		
				Bear.	11.03.98	Niggemann	Anschlußdiagramm 3 Kerne [2 Klemmenkästen]		
				Gepr.		IGW			
							ZN 37021 A		
Zust	Änderung	Datum	Name	(Urspr.)					Blatt
									1
									1 Bl.